



**RESIDENTIAL ELECTRIC SERVICE / PANEL CHANGE**

**JOB ADDRESS** \_\_\_\_\_

**CONTRACTOR OR OWNER NAME** \_\_\_\_\_


**TYPE OF SERVICE:**  
 \_\_\_\_\_ UNDERGROUND  
 \_\_\_\_\_ OVERHEAD

**ALL CONDUCTORS SIZED PER NEC ARTICLE 220  
 ALL UNDERGROUND SERVICE CONDUCTORS MUST HAVE  
 A WARNING RIBBON 12" ABOVE CONDUIT 300.5 (D) (3)**

**SERVICE ENTRANCE**  
 \_\_\_\_\_ CONDUIT SIZE  
 WIRE TYPE ALUMINIUM  COPPER

**PANEL SIZE**  
 \_\_\_\_\_ VOLTAGE RATING  
 \_\_\_\_\_ AMP RATING  
 \_\_\_\_\_ MLO  
 \_\_\_\_\_ MCB

OVERHEAD SERVICE CONDUCTORS SHALL COMPLY WITH NEC 230 PART II

  
 METER OR  
 METER  
 MAIN  
 COMBO

**SERVICE DISCONNECT**  
 WITH OR WITHOUT BRANCH CIRCUIT BREAKERS  
 \_\_\_\_\_ NEW OR  
 \_\_\_\_\_ EXISTING

**SERVICE RATED PANEL**  
 \_\_\_\_\_ VOLTAGE RATING  
 \_\_\_\_\_ AMP RATING  
 \_\_\_\_\_ MAIN BREAKER SIZE  
 \_\_\_\_\_ A.I.C. RATING

**PANEL**  
 \_\_\_\_\_ NEW OR  
 \_\_\_\_\_ EXISTING

**COLD WATER BOND**  
 SIZE \_\_\_\_\_  
 NEC 250.66

**INTERSYSTEM BONDING**  
 NEC 25094

**GROUNDING ELECTRODE CONDUCTOR**  
 SIZE \_\_\_\_\_  
 NEC 250.66

**GROUND ROD**  
 SIZE IN FT \_\_\_\_\_  
 TYPE CU OR GALV

**SUB FEEDER**  
 CONDUIT SIZE \_\_\_\_\_  
 CONDUIT TYPE \_\_\_\_\_  
 WIRE SIZE \_\_\_\_\_  
 EQUIPMENT GROUND WIRE SIZE \_\_\_\_\_  
 WIRE TYPE CU OR ALUMINIUM  
 NEW \_\_\_\_\_  
 OR  
 EXISTING \_\_\_\_\_

**APPROVED BY LICENSED ELECTRICAL CONTRACTOR:** \_\_\_\_\_  
**APPROVED BY HOME OWNER:** \_\_\_\_\_  
 \_\_\_\_\_  
**NOTARY SEAL:**  
**DATE:** \_\_\_\_\_

**City of Oakland Park**  
 APPROVED BY \_\_\_\_\_  
 ELECTRICAL DIVISION